

VERIFICATION OF EMC COMPLIANCE


Applicant: ProJoy Electric Co., Ltd.
Address of applicant: Room 3017, 3018, 30th Floor, Tiancheng Times Business Plaza,
 Xiangcheng District, Suzhou, China
Manufacturer: ProJoy Electric Co., Ltd.
 Room 3017, 3018, 30th Floor, Tiancheng Times Business Plaza,
 Xiangcheng District, Suzhou, China
Product Description: Firefighter Safety Switches
Model No.: PEFS-EL16-2/4/4B/4S/4T/6/8; PEFS-EL25-2/4/4B/4S/4T/6/8;
 PEFS-EL32-2/4/4B/4S/4T/6/8; PEFS-EL40-2/4/4B/4S/4T/6/8
 PEFS-EL55-2/4/4B/4S/4T/6/8;
 PEFS-EL50H-2/4/6/8/10/4B/4T/4S/6T/9T
 PEFS-EL40H-2/4/6/8/10/4B/4T/4S/6T/9T
Rating: DC voltage: 300~1500V, DC current: 9~55A, 1~5 strings;
 AC voltage: 100~270V, AC current: 30~300mA;
 Protection level: IP66
 Sufficient samples of the product have been tested and found to be in conformity with
Test Standard: EN 55014-1:2017, EN 55014-2:2015,
 EN 61000-3-2:2014, EN 61000-3-3:2013
 As shown in the
Test Report Number(s): TEJS20090726745
Date of issue: September 11th, 2020
Date of expiry: September 10th, 2025

Conclusion

This Verification of EMC Compliance has been granted to the applicant based on the results of the TCF, performed by Global Testing Services Co., Ltd. on the sample of the above-mentioned product in accordance with the provisions of the relevant specific standards and the Directive 2014/30/EU. The CE mark as shown below can be used, Under the responsibility of the manufacturer, after completion of an EU Declaration of Conformity and compliance with all relevant EU Directives. The affixing of the CE marking presumes in addition that the conditions in annexes I, II and IV of the Directive are fulfilled.

Approved by: Hermann Weiher

For and on behalf of
 Global Testing Services Co., Ltd




Global Testing Services Co., Ltd
 E-mail: info@gts-lab.com <http://www.gts-lab.com>
 Floor 2nd, Building D-1, No. 128, Shenfu Road, Minhang District, Shanghai, China.